



South Carolina Department of Health
and Environmental Control

PUBLIC NOTICE

Notice # 05574-01

December 7, 2012

This notice is to inform the public that the S. C. Department of Health and Environmental Control (DHEC) is taking public comments on a Corrective Action Plan (CAP). This CAP addresses the cleanup of soil and groundwater contamination at the facility listed below. The contamination was caused by petroleum products that were released from the underground storage tank system at this facility.

FACILITY: Stop N Shop II, 1298 Grace Ave., Lancaster, SC

APPLICANT: Excel Civil & Environmental Associates, PLLC, 625 Huntsman Ct., Gastonia, NC 28054 on behalf of Wilson Gas & Oil Co., Inc. (orphan).

SUMMARY OF CAP: Petroleum and petroleum byproducts naturally break down over time through chemical, physical, and biological processes. These processes are called natural attenuation. Excel Civil & Environmental Associates, PLLC has submitted a CAP proposing the use of the following technologies in addition to natural attenuation to clean up the contamination.

- Free product recovery using a skimming system, followed by recovery using high vacuum extraction and surfactant injection to enhance recovery efforts.

PUBLIC COMMENT PERIOD DEADLINE: The **deadline** for submitting written comments is **5 PM January 7, 2013**. Any interested person(s) may submit written comments concerning the cleanup to DHEC's Project Manager listed below. Please bring this notice to the attention of persons whom you know will be interested in this matter. Where there is a significant degree of public interest, DHEC will hold a public hearing.

Susan B. Fulmer, P.G.
SCDHEC - UST Management Division
2600 Bull Street
Columbia SC 29201
803-896-6676

CONTACT INFORMATION: For additional information, please call the Project Manager listed above. To view a copy of the CAP, contact DHEC's Freedom of Information Office at 803-898-3882.

Section 280.67 of the S.C. Underground Storage Tank Control Regulations (R.61-92) requires that any CAP prepared to meet the requirements of 280.66 be placed on notice for public comment.